



CITY OF MOORPARK

PUBLIC WORKS DEPARTMENT | 323 Science Drive, Moorpark, California 93021
Main City Phone Number (805) 517-6200 | Fax (805) 532-2555 | moorpark@moorparkca.gov

March 06, 2026

ADDENDUM NO. 1

for Specification No. MPK 26-02
2026 Pavement Rehabilitation Project
M0054

There is no change to the bid due date, March 26, 2026, at 3:30 p.m.

NOTICE IS HEREBY GIVEN to all prospective bidders that the following changes, clarifications, and additions are made part of the Notice of Inviting Sealed Bids for the above referenced project and shall be taken into account in the preparation of all proposals and the execution of all work. The changes, clarifications, and/or additions to the Request for Bids are as follows:

1. The Engineer's estimate for the project is \$4,334,626.00.
2. Response to formal inquiries.

Question 1: The specs say all striping shall be removed by wet sand blasting. Can a contractor use the grinding method if they can prove to the engineer that it can be done without leaving deep grooves in the pavement?

Response 1: Page 139 under Section 912-3 PAVEMENT DELINEATION, fourth paragraph, ADD the following paragraph:

All conflicting existing striping and pavement markers, which will not be covered by new construction, shall be removed by mechanical grinding. Painted lines and markings shall be removed by grinding. In areas adjacent to the pavement overlay where existing striping must be revised to conform to revised striping patterns on the overlay, conflicting striping shall be removed by grinding.

Question 2: Appendix F maps, do the different colors and numbers (23)(24) represent years? For example, is this year's project the orange-colored streets?

Response 2: The different colors in Appendix F maps are for internal department planning purposes only and have no bearing on the request for proposal.

[End of Changes]

This Addendum No. 1 shall be made part of the above-referenced project. Full compensation for all work and requirements of this Addendum No. 1 shall be considered as included in the appropriate technical and cost proposals, and no additional compensation will be allowed.



Linda Myszkowski, Assistant Engineer

Questions regarding this addendum may be directed to Linda Myszkowski at (805) 517-6292.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY ATTACHING A SIGNED COPY OF THIS ADDENDUM WITH YOUR BID PROPOSAL. FAILURE TO DO SO MAY RESULT IN DISQUALIFICATION OF YOUR BID.

Company Name

Authorized Representative:

Signature of Authorized Representative:
